

## shopvalves APPROVAL


☐ APPROVED, PROCEED WITH FABRICATION

APPROVED AS NOTED, PROCEED WITH FABRICATION IN ACCORDANCE WITH **COMMENTS** 

☐ DISAPPROVED, DO NOT FABRICATE

77.9±2.0

[1979±51]



## **PROJECT NAME:**

## TAG:

10.0

[254]

TEM	DESCRIPTION	CONNECTION
1	COLD WATER INLET	1" NPT
2	MIXED WATER OUTLET	1" SWT
3	RECIRC WATER INLET	1" NPT
4	STEAM INLET (2)	2" NPT
5	CONDENSATE OUTLET (2)	3/4" NPT 812IB
6	ELECTRICAL PANEL	110VAC @1.4A
7	DRV40 (2)	1-1/2" NPT
8	N.C. ACTUATED BALL VALVE SAFETY SHUT OFF (2)	1" NPT
9	THERMOMETER (3)	1/2" NPT
10	CIP CONNECTION (4)	1" NPT
11	SRV (PRESSURE) PIPE TO DRAIN (2)	1/4" NPT
12	SRV (CONNECTION FOR USER SUPPLIED T&P) (2)	3/4" NPT
13	AIR VENT (2)	3/4" NPT
14	VACUUM BREAKER (2)	1/2" NPT
15	BLOWDOWN (3)	1/2" NPT
16	PRESSURE GAUGE (5)	1/4" NPT
17	BALANCING VALVE (2)	1 " NPT
	ITEM	MATERIAL

TOLERANCES UNLESS OTHERWISE SPECIFIED DIMENSIONING ENGLISH [mm] FRACTIONAL ± 1/64 ANGULAR: ± 2

20.0

[508]

27.4±2.0 [696±51]

Armstrong

**PIPING** 

EXCHANGER SHELL MATL.

EXCHANGER TUBE MATL.

ARMSTRONG INTERNATIONAL Copyright © 2010 ARMSTRONG INTERNATIONAL, INC.

COPPER TYPE "L"

**CARBON STEEL** 

ADMIRALTY BRASS

DF415P40-40

DECIMAL .XXXX ± .0005 .XXX ± .005 .XX ± .015 .X

.010

DATE NAME 5/18/2015

MATERIAL SHEET 1 OF 1 SALES

DRAWN

RELEASED

4. DRV, SAFETY SHUT OFF AND ELECTRICAL PANEL ARE PREWIRED TO PROVIDE A SINGLE ELECTRICAL LANDING POINT AT THE PANEL.