


APPROVAL

BY: _____ DATE: _____

☐ APPROVED, PROCEED WITH FABRICATION



☐ APPROVED AS NOTED, PROCEED WITH FABRICATION IN ACCORDANCE WITH COMMENTS

☐ DISAPPROVED, DO NOT FABRICATE




DIGITAL FLO BOILER WATER/WATER PLATE & FRAME HEAT EXCHANGER DOUBLE WALL

PROJECT NAME :		
TAG :		
ITEM	DESCRIPTION	CONNECTION
1	COLD WATER INLET	1" NPT
2	MIXED WATER OUTLET	1" NPT
3	RECIRC WATER INLET	1" NPT
4A	PRIMARY(BOILER) INLET	1-1/4" NPT
4B	PRIMARY(BOILER) OUTLET	1-1/4" NPT
5	ELECTRICAL PANEL/BRAINSCAN	110VAC @ 1.2A
6	DRV40	1-1/2" NPT
7	N.C. ACTUATED BALL VALVE SAFETY SHUT OFF	1" NPT
8	THERMOMETER (3)	
9	CIP CONNECTION (2)	1" NPT
10	SRV(PRESSURE) PIPE TO DRAIN	1" NPT
11	SRV(CONNECTION FOR USER SUPPLIED T&P)	3/4" NPT
ITEM		MATERIAL
PIPING		COPPER TYPE "L"
EXCHANGER PLATE MATL.		T316L SS
EXCHANGER GASKET MATL.		NITRILE



PIPING AND COMPONENTS
HIDDEN TO SHOW CONNECTIONS



- NOTE(S):
- ALL DIMENSIONS +/- .5[13] UNLESS OTHERWISE SHOWN.
 - COMPLETE ASSEMBLY LEAD FREE COMPLIANT - THE WETTED SURFACE OF THIS PRODUCT CONTACTED BY CONSUMABLE WATER CONTAINS LESS THAN ONE QUARTER OF ONE PERCENT (0.25%) OF LEAD BY WEIGHT.
 - PACKAGE INCLUDES ALL REQUIRED INLET CHECK VALVES AND STRAINERS ON DOMESTIC SIDE.
 - DRV, SAFETY SHUT OFF AND ELECTRICAL PANEL ARE PREWIRED TO PROVIDE A SINGLE ELECTRICAL LANDING POINT AT THE PANEL.

DO NOT SCALE DRAWING
TOLERANCES UNLESS OTHERWISE SPECIFIED
DIMENSIONING
ENGLISH (mm)
FRACTIONAL ± 1/64
ANGULAR ± 2
DECIMAL .XXX ± .0005
XXX ± .005 .010
XX ± .015 .10
X ± .3

NAME
CFG
DATE
02/26/2013

RELEASED
SALES

ARMSTRONG INTERNATIONAL
Copyright © 2010 ARMSTRONG INTERNATIONAL, INC.
DF15WDW40BS 1 NPT CPR
CONFIG# (C-XXXXXX)
SHEET 1 OF 1
DWG. D5XXXXX